

**From:** [Bennett, Jim](#)  
**To:** [Gungle, Ashley](#)  
**Cc:** [Beddow, Donna](#); [Fogg, Mindy](#); [Hingtgen, Robert J](#)  
**Subject:** Soitec Groundwater - Jacumba and Pine Valley  
**Date:** Wednesday, November 20, 2013 3:14:00 PM

---

Hi Ashley,

Here are my review comments for the PVMWC groundwater study and the JCSD groundwater study: <http://webtop-dctm/lueg/drl/objectId/0900f48e80a8b445> Sami indicated she thought we should call Pat first before sending the comments due to their consultant missing the fact that SDG&E is already pumping up to 15,000,000 gallons of water from JCSD for their substation. The good news on this situation is that we have water level records from the well and adjacent well that indicate the pumping that is occurring from SDG&E is having a very minor impact on groundwater supplies so far with 8.8 million gallons removed from April to September.

Thanks,

Jim